

JULY 2010 LUMPKIN CO. PUBLIC BUILDING REPORT

Number of Work Orders

Completed - 85

Open - 3

Number of Community service Workers Placed - 9

Major Projects

Pull Fiber in Conduit at Park & Rec. Building

Replace Rope on Flag Poles at Fire Stations #3 & #5

Huch Tree Service remove tree from Health Dept. Building after wind storm

Cleaned off roof and gutters at Health Dept. from Tree Removal

Meet with Brain Henderson BAA Mechanical Engineers to show him the Mechanical Units and lay out of Buildings. (Court House - Planning and Health Dept.

Meet with Randy Smith and the Electrical Engineers to show him the Electric Panels and Service Entrance at the Court House - Planning and Health Dept.

Justice Center pull 4 - Cat 5 wires from Demor room to Telcom room for Telephone System

Replace Contactor in AC unit #3 at Adult Learning

Install Dehumidifier -Electric outlet and ran a drain line at Adult Learning

Replace Fan Motor on AC unit on Roof of Court House for D. A. Office and charge the unit

Jones Pre K ajust 4 doors

Adult Learning Center clean Coils on 4 inside A C units and set all Thermostats at same set points

Generator - at Annex B Change Oil - Oil Filter & Clean Air Filter

Community Center - worked on water leak at mixing valve

A C unit in D A Office repair wire on contactor - unit was on roof

Annex B - clean coils on outside A C units

Animal Shelter - order gates and install on a kennel for quarantine Dogs to secure from public

Community Center - replace motor on exhaust fan in boiler room

Blairsville Crew Projects

J B Jones Pre K finish floors and move furniture back in rooms

Cut grass on banks at high school (2days)

Help at Recycle Center to catch up on recycling (4days)

Clean Kudzu off fence behind Library

Cleaned Fire Station # 3 - 6 & Airport for Election