



**ITB#2016-009 EXTERIOR DOOR REPLACEMENT AT ADMINISTRATION BUILDING  
QUESTIONS & ANSWERS  
CLARIFICATION ON SPECIFICATIONS  
ADDENDUM 1**

**Return to:** Lumpkin County Board of Commissioners  
Patti Jo Holder, Purchasing Agent  
99 Courthouse Hill, Suite D  
Dahlonega, GA 30533

**Bid Closing Date:** October 12, 2016 at 2:00 PM, EST  
**Bid Issue Date:** September 21, 2016  
**Addendum Issue Date:** October 7, 2016 at 5:00 PM, EST  
**Pages:** 2  
**By:** Patti Holder, Purchasing Agent

**Vendor Name:** \_\_\_\_\_  
(A copy must be attached to the Addenda Acknowledgement)

---

**Questions from Vendors**

Q1. Is the thickness of 1" glass on the door specs correct?

A1. Yes specification is correct.

Q2. Painting or finishing are there anything specifications?

A2. Touchup paint will be handled by staff employees. If any other alterations are made it will be at contractors expense.

**CLARIFICATION ON SPECIFICATIONS**

The specs listed for the 12'x8' Besam electric sliding unit should read as follows:

Furnish and install (1) 12'x 8' Besam electric sliding unit to be installed per manufacture specifications and meet the following specifications: U.S. Aluminum or equivalent meets all current ADA codes; ~~1085 Jackson rod panic bars, intermediate pivots, Yale 5801 parallel arm mount closers,~~ 1" OA glass to match existing or current codes. Sidelites and Transoms are also to be replaced with the same style glass. Doors must be fitted with proper weather seals and sweeps on thresholds.