



**ITB#2016-014 ALL ABILITY BRIDGE AND SIDEWALK  
AT  
LUMPKIN COUNTY PARKS AND RECREATION  
QUESTIONS & ANSWERS  
ADDENDUM 1**

**Return to:** Lumpkin County Board of Commissioners  
Patti Jo Holder, Purchasing Agent  
99 Courthouse Hill, Suite D  
Dahlonega, GA 30533

**Bid Closing Date:** November 15, 2016 at 10:00 AM, EST

**Bid Issue Date:** October 26, 2106

**Addendum Issue Date:** November 8, 2016 at 5:00 PM, EST

**Pages:** 1

**By:** Patti Holder, Purchasing Agent

**Vendor Name:** \_\_\_\_\_  
(A copy must be attached to the Addenda Acknowledgement)

---

**Questions from Vendors**

Q1. In regard to the pedestrian bridge is there further detail on what grade the materials are to be, weathering steel, painted, etc.?

A1. The steel will be 46ksi painted.

Q2. Since it appears the design is complete it is just build to print and no engineering documents will need to be provided?

A2. That is correct build as designed.